

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0900:117 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Fike Corporation, 704 S. 10th Street, Blue Springs, MO 64015
Contact: Sean Titus (816) 229-3405

DESIGN: Models 55-030 and 55-031 Addressable Input Modules. Models 55-030 and 55-031 provide additional input circuits.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with Silent Knight's separately listed Model 5820 fire alarm control unit (CSFM Listing No. 7165-0559:130).

XLF: 7300-0559-132

05-26-02 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager